

SUGGESTED SPECIFICATIONS

Note To Consultants and Designers: Use this document as a guide when writing specifications for Storage Tank Liquid Level Management Systems requiring 0.1 GPH or 0.2 GPH In-Tank leak detection, and/or secondary containment leak detection capabilities, which meet or exceed the current Standard EPA required protocols.

Client _____

Project Name _____

Project Number _____

EPA Compliant TMS4000M Color, Touchscreen-based Precision In-Tank Liquid Level Control and External Leak Sensor Management System for both Underground and Aboveground Liquid Storage Tanks

I. General: These specifications are provided to prospective bidders and engineering consultants as a guide to understanding the requirements relative to furnishing and installing an electronic monitoring system for underground liquid storage tanks (USTs), associated buried piping and containment areas. This document will address and describe the capabilities and performance standards of the model **TMS4000M** Tank Management and Leak Detection system as set forth and in accordance with the USEPA Federal standards for (USTs) as described in Subpart D, 40 CFR Part 280.

II. Relevant Documents: The tank monitoring system shall meet all of the applicable performance specifications and regulatory agency requirements set forth by the following organizations:

- American Petroleum Institute (API)
- American Society for Testing and Materials (ASTM)
- Environmental Protection Agency (EPA)
- Federal Communications Commission (FCC)
- National Electric Code (NEC)
- National Fire Protection Agency (NFPA)
- Underground Storage Tank: Subpart D, 40 CFR Part 280
- Underwriters Laboratories (UL)

SUGGESTED SPECIFICATIONS

III. Tank Management Console: The console shall be microprocessor-based, and shall be designed and constructed with modular architecture easily permitting either factory or field upgrades and servicing. The console shall be housed in a lockable, wall-mounted or panel-mount NEMA 12 enclosure, and shall optionally be available in a NEMA 4X, weatherproof and corrosion-proof outdoor configuration. The user interface shall be a 7" color SVGA LCD display with integral touchscreen having a minimum 2mm thick protective glass touch surface. To assure durability, the touchscreen glass shall be chemically treated to provide a minimum 7H hardness. Touchscreen surfaces made from plastic materials shall not be acceptable. Gloved-hand operation shall be supported when installed outdoors, and manufacturer shall guarantee the display against fogging or the collection of condensate on the interior of the viewing window. Screen saver modes shall be provided to enhance display longevity. Display presentation shall provide real-time tank measurement data, statuses and alarms in three different formats simultaneously; large-font numerics readable from 50'; detailed spreadsheet; and quick-view bar graphs. Each format shall be user-configurable, and active or alarming tanks shall have visual priority. Dedicated touch buttons shall be provided for quick access to alarm conditions and display brightness control. Dedicated front panel LEDs shall be provided to indicate POWER, NORMAL and ALARM conditions.

System shall maintain set-up and configuration files in non-volatile memory having a minimum fifty (50) year data retention without requiring power of any kind, and shall provide a means for importing or exporting these files via USB flash drive or through serial, Ethernet or cellular communications. Historical log data, such as inventory, delivery, bulk sales, theft, water removal, product order, alarm, error, tank leak, and leak history reports shall be maintained in non-volatile, removable SD card memory format with a minimum fifty (50) year data retention in the event of a power outage. All log data shall be encrypted for security purposes. A Real-Time clock shall be provided and maintained with a high-value capacitor for maintenance-free operation.

E-mail alerts and Web-based access to real-time data and alarms, historical logs, configuration and firmware updates shall be supported as standard feature via Ethernet TCP/IP or optional cellular connectivity.

The system shall be independently third-party certified for UST petroleum storage tanks and have the capability to automatically or manually conduct a static volumetric tank tightness test to an accuracy of 0.2 GPH for monthly monitoring and 0.1 GPH for annual precision testing, with minimum test times of two hours and eight hours respectively. System shall be capable of performing both tests with as little as 20% of tank capacity. The system shall also be independently third-party certified for secondary containment leak detection, including 3 GPH catastrophic line leak detection on pressurized piping systems.

3A. Intrinsically Safe Probe/Sensor Inputs: Console shall have the capability to continuously monitor up to four (4) dual-float magnetostrictive in-tank level probes and up to eight (8) secondary containment leak or point-level sensors. Leak and point-level sensor inputs shall support a means to detect sensor open-circuit and short-circuit wiring faults as a standard feature when used in conjunction with fault-reporting sensors.

SUGGESTED SPECIFICATIONS

3B. Non-Intrinsically Safe Inputs: Console shall include two (2) programmable relay outputs and two (2) contact closure inputs and have provisions for accepting one (1) non-hazardous I/O expansion card providing support for optional relay or analog output cards. Console shall have support for up to 10 relay outputs, and all relays and contact closure inputs shall be user-programmable for activation by the following event types; Theft, Power Fail Recovery, System Error, Tank Leak, Product Setpoints, Water Setpoints, Temperature Setpoints, Leak/Point Level Sensors, Contact Closure inputs and Line Leak. Optional 4-channel Analog Output card shall be available to provide 0-20mA / 4-20mA / 0-24mA / 0-1mA signals for tank-related real-time data. I/O options shall include:

- 4 Input/4 Output Relay Card, Pneumercator **Part Number 901042-1**
- 8 Output Relay Card, Pneumercator **Part Number 901044-1**
- 4-channel Analog Output Card (one per console), Pneumercator **Part Number 901043-1**

3C. Communications: Standard communications shall include Ethernet TCP/IP, USB host and client, two (2) RS-232 serial ports and one (1) RS-485 serial port for connection to "smart" peripherals, such as remote "slave" display and annunciator panels. Options shall be available for up to one (1) additional RS-232 or three (3) Modbus RS-485 ports, telephone modem or cellular modem. Communications options shall include:

- 14,400 Baud Modem, Pneumercator **Part Number 900433-10**
- Auxiliary RS-232 Interface Card, Pneumercator **Part Number 900571-2**
- Modbus RTU Interface Card, Pneumercator **Part Number 900552-10**
- Isolated Modbus RTU Interface Card, Pneumercator **Part Number 901050-10**
- Dual-Modbus RTU Interface Card, Pneumercator **Part Number 900665-5-5**
- Isolated, Dual-Modbus RTU Interface Card, Pneumercator **Part Number 900665-R-R**
- Cellular Modem, Pneumercator **Part Number 901040-1**

3D. Input Power: Standard system power supply shall automatically operate on 95-250 VAC, 50/60 Hz, and options shall be provided for 10-50 VDC negative ground sources. Maximum power consumption shall be 30 watts.

3E. Hardcopy Reports: The system shall support an external thermal printer providing 48-column portrait mode or 133-column landscape mode hardcopy reports. Printer option shall be field-upgradeable and be available for indoor use only. External Printer option shall be:

- External Thermal Printer **Part Number TPE325-1**

Console shall be Pneumercator **Model Series TMS4000M**.

SUGGESTED SPECIFICATIONS

IV. Tank Gauging Probe: Probe shall be designed for both AST and UST applications and shall have performance characteristics permitting 0.1 GPH or better in-tank leak test with continuous gauging accuracy of +/- 0.0005 inches for product, +/- 0.001 inches for water and +/- 0.001°F for (relative) temperature. Probe shall contain an array of at least five (5) temperature sensors along its length for accurate volumetric temperature compensation. Probe to console communication shall employ digital transmission techniques carried over standard, readily available two-conductor, shielded cable, with a maximum cable length restriction of no less than 4000 feet. Probe operating temperature and pressure shall be -40°F to +175°F and 150 PSIG respectively. Probes shall be supplied with product float, water float, six (6) foot leader cable with watertight connector, and centering rings for riser mounted applications. Probe shall be UL/CSA approved for use in Class I, Division I, Group D hazardous locations.

Probe shall be Pneumercator **Model MP450S** for rigid lengths from 24 to 216 inches.

Probe shall be Pneumercator **Model MP451S** for rigid lengths from 217 to 288 inches.

Probe shall be Pneumercator **Model MP452S** for oil/water separator tanks.

Probe shall be Pneumercator **Model MP461S** for flexible lengths from 12 to 216 inches.

Probe shall be Pneumercator **Model MP462S** for flexible lengths from 217 to 288 inches.

Probe shall be Pneumercator **Model MP463S** for flexible lengths from 289 to 600 inches.

Probe shall be Pneumercator **Model MP464S** for flexible lengths from 601 to 840 inches.

SUGGESTED SPECIFICATIONS

V. Point/Level Sensors: Single and multi-float level sensors shall be available for overfill, high, low, pump-on and pump-off liquid level detection in above and underground storage tanks, with standard 2-inch (50mm) or optional 1.5-inch (38mm) or 4-inch (100mm) mild steel mounting bushing or 150# flange, optional 2-inch (50mm) or 4-inch (100mm) stainless-steel bushing or 150# flange, or optional 2-inch (50mm) or 4-inch (100mm) PVC bushing. Sensor shall be available with a means for testing operation of the highest positioned float without removing sensor from tank. Standard wetted materials of construction shall be a brass stem and buna-nitrile float, with stainless-steel, PVC and CPVC options. All sensors shall be available with a wiring fault detection feature. Optional wiring housing shall be O-ring gasketed and rated NEMA 4X.

Level sensor shall be Pneumercator **Model Series LS600**

5A. Alternate sub-base generator and small tank single and multi-float level sensor shall install into a minimum 1-inch (25mm) NPT opening and shall have a not-to-exceed switch-to-switch clearance of 1.5-inch (38mm) and a not-to-exceed switch-to-bottom of stem clearance of 0.875-inches (22mm).

Sub-base generator and small tank single and multi-float level sensor shall be
Pneumercator **Model Series LS600M**.

5B. Alternate large bulk tank and heated #6 oil tank single and multi-float level sensor shall have a minimum 0.625-inches (16mm) diameter stainless-steel stem with 4-inch (100mm) mild or stainless-steel bushing or 150# flange. Float(s) shall be stainless-steel with a minimum 3.5-inches (90mm) diameter and be optionally available with a means for testing operation of the highest positioned float without removing sensor from tank.

Large bulk tank and heated #6 oil tank single and multi-float level sensor shall be
Pneumercator **Model Series LS600F4**.

5C. Alternate water-submersible single and multi-float level sensor shall have a double-sealed construction with integral minimum 20-foot (6M) submersible polyethylene-jacketed wiring cable suitable for installation in a minimum 2-inch (50mm) NPT opening. Sensor shall be submersible to a depth of 10' of water. Standard construction shall be 316 stainless-steel 2-inch (50mm) bushing, stem and float(s), with optional 2-inch (50mm) PVC bushing and stem, optional 1.5-inch (38mm), 2-inch (50mm) or 4-inch (100mm) 316 stainless-steel 150# flange, and optional buna-nitrile or polypropylene float(s).

Water-submersible single and multi-float level sensor shall be Pneumercator **Model Series LS600X**.

5D. Alternate oil/water separator tank single and multi-float level sensor shall have the ability to detect a combination of multiple oil/water interface levels and water levels. Standard materials of construction shall be brass stem, 316 stainless-steel float(s) and 2-inch (50mm) mild steel bushing, with optional 4-inch (100mm) mild steel bushing, 2-inch (50mm) or 4-inch (100mm) mild or 316 stainless-steel 150# flange.

Oil/water separator tank single and multi-float level sensor shall be
Pneumercator **Model Series LS600W**.

SUGGESTED SPECIFICATIONS

VI. Secondary Containment Leak Sensors: Both non-discriminating and product/water-discriminating leak sensors shall be available for liquid detection in interstitial spaces, containment areas, sumps, brine reservoirs, dispenser pans and piping locations. All sensors shall be optionally available with a wiring fault detection feature.

Non-Discriminating Type Liquid Sensors

6A. Alternate sump, dispenser pan and steel tank double-wall sensor shall be a 2-wire type consisting of a magnetic, Buna-N float encased within a 1-1/2-inch (38mm) diameter, stainless-steel outer housing and supplied with twenty-five (25) feet (7M) of 2-conductor #22 AWG gage wire. Sensor shall be rated to 50 PSIG at 160°F (70°C) with an accuracy of 1/2-inch (13mm) of liquid. Optional configuration utilizing 1-3/4-inch (45mm) diameter stainless-steel/Teflon housing, stainless-steel float and Teflon-jacketed cable shall be available for solvent/fuel additive applications. Sensors shall optionally be available with tamper-resistant feature to detect improper installation. All sensors shall be available with wiring fault detection option [F].

Petroleum sump, dispenser pan and steel tank double-wall leak sensor shall be

Pneumercator **Model LS600LDBN-1-[F]**.

Petroleum sump, disp. pan and steel tank double-wall leak sensor with tamper-resistant feature shall be

Pneumercator **Model LS600LDBN-1-FT**.

Solvent sump, dispenser pan and steel tank double-wall leak sensor shall be

Pneumercator **Model LS600LDSS-[F]**.

Solvent sump, disp. pan and steel tank double-wall leak sensor with tamper-resistant feature shall be

Pneumercator **Model LS600LDSS-FT**.

6B. Alternate dispenser pan or fiberglass tank annular sensor shall be a 2-wire type consisting of a horizontally oriented magnetic float encased within a fabricated PVC outer housing and supplied with twenty-five (25) feet (7M) of 2 conductor #22 AWG gage wire. Sensor shall pass through a fiberglass double-wall tank annular space tank opening. Sensor shall provide an accuracy of 1/2 inch (13mm) of liquid.

Dispenser pan or fiberglass tank annular leak sensor shall be Pneumercator **Model LS610**.

6C. Wet annular reservoir sensor shall be 3-wire type consisting of dual magnetic floats capable of detecting breached inner or outer walls of a double-wall fiberglass tank. The reservoir sensor and its components shall be provided with a non-corroding PVC outer housing, float and guide stem assembly, and sixteen (16) feet (5M) of 3-conductor #22 AWG gage wire. Sensor shall mount in a specified manway on top of each tank and rest on the reservoir floor. The Hydrostatic sensor shall detect changes in the reservoir brine or glycol solution when the level drops below 2 inches (5cm) or rises above 11 inches (28cm) of liquid. An alternate 2-wire type shall be available with built-in wiring fault detection.

3-wire wet annular reservoir leak sensor shall be Pneumercator **Model RSU800-2**.

2-wire wet annular reservoir leak sensor shall be Pneumercator **Model RSU801F**.

SUGGESTED SPECIFICATIONS

6D. An electronic sump, dispenser pan and dry annular sensor utilizing optical technology and no moving parts shall be available to sense the presence of liquid within a secondary containment space. Sensor shall operate reliably with cable lengths up to 4000 feet (1200M) and shall include both wiring and sensor fault detection as a standard feature. Sensor assembly shall be provided with a twenty-five (25) foot (7M), 3-conductor, #22 AWG gage wire cable. Sensor shall be optionally available with an extended low operating temperature of -40°F (-40°C) with FEP-jacketed 20-foot (6M) cable. Sensor shall be optionally available in all PFA construction with FEP-jacketed 20-foot (6M) cable suitable for use in solvent or chemical applications.

Electro-optical sump, dispenser pan and dry annular leak sensor shall be
Pneumercator **Model ES 825-100F**. (Standard)

Electro-optical sump, dispenser pan and dry annular leak sensor shall be
Pneumercator **Model ES 825-100XF**. (Extended Temperature)

Electro-optical sump, dispenser pan and dry annular leak sensor shall be
Pneumercator **Model ES 825-100CF**. (Chemical/Solvent Resistant)

Discriminating Type Liquid Sensors

6E. A discriminating electronic sump, dispenser pan and dry annular sensor utilizing both electro-optical and conductivity technologies shall be available for detecting and differentiating between the presence liquid hydrocarbon and water within a secondary containment space. Sensor shall operate reliably with cable lengths up to 4000 feet (1200M) and shall include both wiring and sensor fault detection as a standard feature. Sensor assemblies shall be provided with a twenty-five (25) foot (7M), 3-conductor, #22 AWG gage wire cable. Sensor shall be optionally available with an extended low operating temperature of -40°F (-40°C) with FEP-jacketed 20-foot (6M) cable.

Discriminating sump, dispenser pan and dry annular leak sensor shall be
Pneumercator **Model ES 825-200F**. (Standard)

Discriminating sump, dispenser pan and dry annular leak sensor shall be
Pneumercator **Model ES 825-200XF**. (Extended Temperature)

6F. A discriminating, flexible electronic wet well sensor utilizing conductive polymer technology shall be available for detecting the presence of hydrocarbon-based liquids floating on water anywhere along its sensing length. The sensor shall be unaffected by the presence of water or hydrocarbon vapor. Sensor shall operate reliably with cable lengths up to 4000 feet (1200M). Sensor assembly shall be provided with a 4-foot (1.3M), 3-conductor leader cable with mating sensor connector. Sensor shall provide separate alarms for “hydrocarbon present” or “dry well” conditions.

Wet well leak sensor shall be Pneumercator **Model HS100D2**.

6G. A discriminating, flexible electronic wet well sensor utilizing conductive polymer technology shall be available for detecting the presence of hydrocarbon-based liquids floating on water anywhere along its sensing length. The sensor shall be unaffected by the presence of water or hydrocarbon vapor. Sensor shall operate reliably with cable lengths up to 4000 feet (1200M). Sensor assembly shall be supplied with twenty-five (25) feet (7M), 2-conductor #22 AWG leader cable. Sensor shall alarm for “hydrocarbon present” condition only. Sensing element shall be available in lengths up to 45’ feet (14M).

Dry containment hydrocarbon-only leak sensor shall be Pneumercator **Model HS100ND**

SUGGESTED SPECIFICATIONS

6H. A USEPA-compliant line leak sensor shall be available for detecting a 3 GPH catastrophic leak on pressurized liquid piping systems operating at up to 120 psi. A detected leak shall provide an audible/visual alarm, and in support of critical power applications, shall be programmable to enable or disable pump shutdown. All wetted components of the sensing body shall be constructed of 316SS, and the exterior housing shall be available in aluminum or 316SS. Sensor shall operate reliably with cable lengths up to 4000 feet. Sensor assembly shall be supplied with weathertight, quick-disconnect and six (6) foot leader cable.

3 GPH Pressure Line Leak sensor with aluminum outer housing shall be

Pneumercator **Model LLP203-1**

3 GPH Pressure Line Leak sensor with 316SS outer housing shall be

Pneumercator **Model LLP203-2**

3 GPH Pressure Line Leak sensor with Hastelloy C-276 outer housing shall be

Pneumercator **Model LLP203-3**

VII. External Remote Audible/Visual Displays and Annunciators:

7A. Remote Audible/Visual Alarm Annunciator shall consist of a solid-state electronic wall-mounted Strobe/Siren combination housed in a NEMA 4X weatherproof enclosure. The audible annunciator shall have a minimum rating of 110db at three (3) feet (1M). The visual annunciator shall be a superbright, multi-directional LED array with a minimum rating of seventy-five (75) candelas. Multiple annunciators shall have the capability of being connected in a daisy chain or parallel configuration. A separate Test/Reset remote switch assembly shall also be available in a NEMA 4X enclosure to be used in conjunction with the remote audible/visual alarm, permitting the annunciator to be mounted with an optimal mounting height for maximum visual and audible range, yet providing access to Test/Reset functions. Acknowledging alarms shall only silence the audible alarm, while the visual alarm remains until the condition is corrected. The Test button shall be provided to verify operation of both the audible and visual alarms. System shall operate on switch selectable 115/230VAC (+/- 10%), 50/60 Hz line voltage. Maximum power consumption shall be less than 8 watts.

External Remote Annunciator shall be Pneumercator **Model RA210**.

Optional External Remote Test/Reset Switch Assembly shall be Pneumercator **Model RS2**.

7B. An electronic remote audible/visual alarm shall provide independent, remote annunciation of user-selected alarms from a distance up to 4000 feet (1200M) from the main console. Communications shall be over an RS-485 multi-drop topology supporting the connection of up to 16 remote annunciators to one tank management system. The remote annunciator shall be housed in a NEMA 4X enclosure for harsh industrial/outdoor environments. The visual alarm shall be sunlight-readable LED technology for maximum reliability in extreme temperatures, visible from at least 200 feet (60M). Front panel horn shall have a minimum 110dB rating. Pushbutton controls shall be provided for audible/visual test and audible silence. Pushbuttons shall be minimum one inch on centers for easy operation with gloved hands.

External Remote Audible/Visual Alarm shall be Pneumercator **Model RA400**

SUGGESTED SPECIFICATIONS

7C. An electronic tank display shall provide independent, remote access to all real-time tank data and alarms from a distance up to 4000 feet from the main console. Communications shall be over an RS-485 multi-drop topology supporting the connection of up to 16 remote displays to one tank management system. The remote display shall be housed in a lockable, wall-mounted or panel-mount NEMA 12 enclosure, and shall optionally be available in a NEMA 4X, weatherproof and corrosion-proof outdoor configuration. The user interface shall be a 7" color SVGA LCD display with integral touchscreen having a minimum 2mm thick protective glass touch surface. To assure durability, the touchscreen glass shall be chemically treated to provide a minimum 7H hardness. Touchscreen surfaces made from plastic materials shall not be acceptable. Gloved-hand operation shall be supported when installed outdoors, and manufacturer shall guarantee the display against fogging or the collection of condensate on the interior of the viewing window. Screen saver modes shall be provided to enhance display longevity. Display presentation shall provide real-time tank measurement data, statuses and alarms in two different formats simultaneously; large-font numerics readable from 50'; and quick-view bar graphs. Each format shall be user-configurable, and active or alarming tanks shall have visual priority. Dedicated touch buttons shall be provided for quick access to alarm conditions and display brightness control. Dedicated front panel LEDs shall be provided to indicate POWER, NORMAL and ALARM conditions.

External Remote Electronic Tank Display shall be Pneumercator **Model ETD1000T**

7D. An electronic tank display shall provide independent, remote access to all real-time tank data and alarms from a distance up to 4000 feet from the main console. Communications shall be over an RS-485 multi-drop topology supporting the connection of up to 16 remote displays to one tank management system. The remote display shall be housed in a NEMA 4X enclosure for harsh industrial/outdoor environments. The display shall be sunlight-readable LED technology for maximum reliability in extreme temperatures. Pushbutton controls shall be one inch on centers for easy operation with gloved hands.

External Remote Electronic Tank Display shall be Pneumercator **Model ETD1000**

7E. An electronic remote audible/visual alarm shall provide independent, remote annunciation of user-selected alarms via wireless 900Mhz or 2.4Ghz radio supporting the connection of up to 16 remote annunciators to one tank management system via a single wireless peripheral server. The remote annunciator and wireless server shall be housed in NEMA 4X enclosures for harsh industrial/outdoor environments. The visual alarm shall be sunlight-readable LED technology for maximum reliability in extreme temperatures, visible from at least 200 feet (60M). Front panel horn shall have a minimum 100dB rating. Pushbutton controls shall be provided for audible/visual test and audible silence. Pushbuttons shall be minimum one inch on centers for easy operation with gloved hands.

External Wireless Remote Audible/Visual Alarm shall be Pneumercator **Model RA400W**

External Wireless Peripheral Server shall be Pneumercator **Model MPX200**

7F. An electronic tank display shall provide independent, remote access to all real-time tank data and alarms via wireless 900Mhz or 2.4Ghz radio supporting the connection of up to 16 remote displays to one tank management system via a single wireless peripheral server. The remote annunciator and wireless server shall be housed in NEMA 4X enclosures for harsh industrial/outdoor environments. The display shall be sunlight-readable LED technology for maximum reliability in extreme temperatures. Pushbutton controls shall be one inch on centers for easy operation with gloved hands.

External Wireless Remote Electronic Tank Display shall be Pneumercator **Model ETD1000W**

External Wireless Peripheral Server shall be Pneumercator **Model MPX200**

SUGGESTED SPECIFICATIONS

VIII. Acceptable Products:

1. Control Console shall be Pneumercator Model **TMS4000M**.
2. Probe shall be Pneumercator **Model MP450S** for rigid lengths from 24 to 216 inches.
Probe shall be Pneumercator **Model MP451S** for rigid lengths from 217 to 288 inches.
Probe shall be Pneumercator **Model MP452S** for oil/water separator tanks.
Probe shall be Pneumercator **Model MP461S** for flexible lengths from 12 to 216 inches.
Probe shall be Pneumercator **Model MP462S** for flexible lengths from 217 to 288 inches.
Probe shall be Pneumercator **Model MP463S** for flexible lengths from 289 to 600 inches.
Probe shall be Pneumercator **Model MP464S** for flexible lengths from 601 to 840 inches.
3. Level sensor shall be Pneumercator **Model LS600** for single and multipoint level sensing.
Level sensor shall be Pneumercator **Model LS600M** for sub-base and small tank level sensing.
Level sensor shall be Pneumercator **Model LS600F4** for bulk and heated #6 oil tank level sensing.
Level sensor shall be Pneumercator **Model LS600X** for water-submergible tank level sensing.
Level sensor shall be Pneumercator **Model LS600W** for oil/water separator tank level sensing.
- 4a. Petroleum sump, dispenser pan and steel tank double-wall leak sensor shall be
Pneumercator **Model LS600LDBN-1-[F]** or **LS600LDBN-1-FT** with tamper-resistant feature.
- 4b. Solvent sump, dispenser pan and steel tank double-wall leak sensor shall be
Pneumercator **Model LS600LDSS-[F]** or **LS600LDSS-1-FT** with tamper-resistant feature.
5. Dispenser pan or fiberglass tank annular leak sensor shall be Pneumercator **Model LS610**.
- 6a. 3-wire wet annular reservoir leak sensor shall be Pneumercator **Model RSU800-2**.
- 6b. 2-wire wet annular reservoir leak sensor shall be Pneumercator **Model RSU801F**.
- 7a. Electro-optical sump, dispenser pan and dry annular leak sensor shall be
Pneumercator **Model ES 825-100F**. (Standard)
- 7b. Electro-optical sump, dispenser pan and dry annular leak sensor shall be
Pneumercator **Model ES 825-100XF**. (Extended Temperature)
- 7c. Electro-optical sump, dispenser pan and dry annular leak sensor shall be
Pneumercator **Model ES 825-100CF**. (Chemical/Solvent Resistant)
- 8a. Discriminating sump, dispenser pan and dry annular leak sensor shall be
Pneumercator **Model ES 825-200F**. (Standard)
- 8b. Discriminating sump, dispenser pan and dry annular leak sensor shall be
Pneumercator **Model ES 825-200XF**. (Extended Temperature)
9. Wet well hydrocarbon leak sensor shall be Pneumercator **Model HS100D2**.
10. Hydrocarbon leak sensor shall be Pneumercator **Model HS100ND**.
- 11a. 3 GPH Catastrophic line leak sensor with aluminum outer housing shall be
Pneumercator **Model LLP203-1**
- 11b. 3 GPH Catastrophic line leak sensor with 316SS outer housing shall be
Pneumercator **Model LLP203-2**
- 11c. 3 GPH Catastrophic line leak sensor with Hastelloy C-276 outer housing shall be
Pneumercator **Model LLP203-3**
- 12a. External Remote Annunciator shall be Pneumercator **Model RA210**.
- 12b. Optional External Remote Test/Reset Switch Assembly shall be Pneumercator **Model RS2**.
13. External Remote Audible/Visual Alarm shall be Pneumercator **Model RA400**
14. External Remote Electronic Touchscreen Display shall be Pneumercator **Model ETD1000T**
15. External Remote Electronic Tank Display shall be Pneumercator **Model ETD1000**
16. External Wireless Remote Audible/Visual Alarm shall be Pneumercator **Model RA400W**
17. External Wireless Remote Electronic Tank Display shall be Pneumercator **Model ETD1000W**
18. External Wireless Peripheral Server shall be Pneumercator **Model MPX200**